# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18

Date: 16.02.2018

## TEST REPORT ON CONCRETE CUBES

| | |
|---|---|
| Client | : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore. |
| Contractor | : **Sri. N.M Krishnamurthy,** Contractor, Bangalore. |
| Name of the work | : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore. |
| Sample ID | : Cement Concrete |
| Size of cubes | : 150mmx150mmx150mm |
| Cross Sectional Area | : 22500 $mm^2$ |
| Technical Reference | : IS: 516-1959 (Reaffirmed 2008) |
| Grade of Concrete | : $M_{10}$ |
| Compressive Strength as on | : 28th day |

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 16.02.2018 | 8.165 | 280.6 | 12.47 |
| 2 | 19.01.2018 | 16.02.2018 | 8.152 | 269.2 | 11.96 |
| 3 | 19.01.2018 | 16.02.2018 | 8.149 | 294.3 | 13.08 |

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
*NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory*

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18 Date: 26.01.2018

## TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.

Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 $mm^2$
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : $M_{10}$
Compressive Strength as on : 7th day

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 26.01.2018 | 8.122 | 168.2 | 7.48 |
| 2 | 19.01.2018 | 26.01.2018 | 8.134 | 170.9 | 7.60 |
| 3 | 19.01.2018 | 26.01.2018 | 8.152 | 183.4 | 8.15 |

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED


Job No.: CQCE/BBMP/NMK/W.No.16/2017-18 Date: 16.02.2018

## TEST REPORT ON CONCRETE CUBES

| | |
|---|---|
| Client | : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore. |
| Contractor | : **Sri. N.M Krishnamurthy,** Contractor, Bangalore. |
| Name of the work | : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore. |
| Sample ID | : Cement Concrete |
| Size of cubes | : 150mmx150mmx150mm |
| Cross Sectional Area | : 22500 $mm^2$ |
| Technical Reference | : IS: 516-1959 (Reaffirmed 2008) |
| Grade of Concrete | : $M_{10}$ |
| Compressive Strength as on | : 28th day |

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 16.02.2018 | 8.145 | 258.2 | 11.48 |
| 2 | 19.01.2018 | 16.02.2018 | 8.166 | 269.5 | 11.98 |
| 3 | 19.01.2018 | 16.02.2018 | 8.152 | 275.4 | 12.24 |

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

ನಿವಾಯಿಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬಿಬಿಎಂಪಿ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Authorised Signatory


Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550


Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
*NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory*

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18 Date: 26.01.2018

## TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.
Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 $mm^2$
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : $M_{10}$
Compressive Strength as on : 7th day

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 26.01.2018 | 8.133 | 165.2 | 7.34 |
| 2 | 19.01.2018 | 26.01.2018 | 8.129 | 178.2 | 7.92 |
| 3 | 19.01.2018 | 26.01.2018 | 8.119 | 186.4 | 8.28 |

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18 Date: 16.02.2018

## TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.
Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 $mm^2$
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : $M_{10}$
Compressive Strength as on : 28th day

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 16.02.2018 | 8.168 | 268.5 | 11.93 |
| 2 | 19.01.2018 | 16.02.2018 | 8.175 | 289.2 | 12.85 |
| 3 | 19.01.2018 | 16.02.2018 | 8.150 | 255.3 | 11.35 |

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
*NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory*

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18

Date: 26.01.2018

## TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.
Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 $mm^2$
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : $M_{10}$
Compressive Strength as on : 7th day

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 26.01.2018 | 8.115 | 182.5 | 8.11 |
| 2 | 19.01.2018 | 26.01.2018 | 8.128 | 169.2 | 7.52 |
| 3 | 19.01.2018 | 26.01.2018 | 8.130 | 175.3 | 7.79 |

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
*NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory*

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18 Date: 16.02.2018

## TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.
Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 $mm^2$
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : $M_{10}$
Compressive Strength as on : 28th day

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 16.02.2018 | 8.168 | 285.6 | 12.69 |
| 2 | 19.01.2018 | 16.02.2018 | 8.154 | 278.9 | 12.40 |
| 3 | 19.01.2018 | 16.02.2018 | 8.140 | 298.1 | 13.25 |

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
*NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory*

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18 Date: 26.01.2018

## TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.

Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 $mm^2$
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : $M_{10}$
Compressive Strength as on : 7th day

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 26.01.2018 | 8.120 | 165.8 | 7.37 |
| 2 | 19.01.2018 | 26.01.2018 | 8.136 | 175.2 | 7.79 |
| 3 | 19.01.2018 | 26.01.2018 | 8.115 | 189.3 | 8.41 |

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
*NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory*

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18 Date: 16.02.2018

## TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.

Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 $mm^2$
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : $M_{10}$
Compressive Strength as on : 28th day

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 16.02.2018 | 8.156 | 259.5 | 11.53 |
| 2 | 19.01.2018 | 16.02.2018 | 8.164 | 266.2 | 11.83 |
| 3 | 19.01.2018 | 16.02.2018 | 8.150 | 278.1 | 12.36 |

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

# CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
*NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory*

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18 Date: 26.01.2018

## TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.

Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 $mm^2$
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : $M_{10}$
Compressive Strength as on : 7th day

| Sl.No. | Date of casting | Date of testing | Weight of cube (Kg) | Failure load (KN) | Compressive strength ($N/mm^2$) |
|---|---|---|---|---|---|
| 1 | 19.01.2018 | 26.01.2018 | 8.136 | 168.2 | 7.48 |
| 2 | 19.01.2018 | 26.01.2018 | 8.120 | 179.2 | 7.96 |
| 3 | 19.01.2018 | 26.01.2018 | 8.118 | 180.3 | 8.01 |

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner